

CERTIFICATE OF COMPLIANCE

Certificate Number 20191022-E331591
Report Reference E331591-20191017
Issue Date 2019-OCTOBER-22

Issued to: Signify North America Corporation
3 Burlington Woods Dr
Burlington MA 01803

**This certificate confirms that
representative samples of**

MANAGEMENT EQUIPMENT, ENERGY
Open-Type Energy Management Equipment; Ethernet
Gateway Controller, Model PDDEG-S.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 916 The Standard for Energy Management Equipment
CAN/CSA-22.2 No. 205 The Standard for Signal Equipment

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

